
TECHNICAL RANGE

The Complete Pipe Fitting's Handbook



CONTENTS

	PAGE
Compression Fittings Introduction	1
Copper Tubing for Economy	2
Making a Compression Joint	3
Compression Fittings	4
Gate Valves	18
Stop Taps	19
Capillary Fittings Introduction	20
Making a Capillary Joint	22
Capillary Fittings	22
Copper Tubing for Domestic Plumbing	38



Special Note

Throughout this booklet sizes for unequal ends of tees have been given in the number order as indicated above. When ordering, use the same system, the branch size always being stated last.

All imperial sizes quoted refer to ends for BSP thread connections. All metric sizes quoted refer to nominal sizes for copper tubes to SABS.

In the compression range both male and female connecting threads are BSP parallel.

In the capillary range all male connecting threads are BSP Taper. All female connecting threads are BSP parallel.

INTRODUCTION

Compression Fittings

The compression ring type copper tube joining system was designed and introduced in the United Kingdom in 1933. Cobra introduced it to the South African market in the early 1950's, under the "Conex" brand at the time and in recent years under the COBRA brand.

The versatility, efficiency and jointing speed led to its rapid adoption by plumbing contractors. The introduction of Hard Drawn Copper Tube has led to the wider use of copper tube systems in inland areas. Cobra compression is suitable for use with hard drawn [SANS 460 class 0] tubing as well. Inland contractors have discovered that with Cobra compression fittings they can use cheaper, less skilled labour. It is a much faster system to install than the ones used traditionally and the range of fittings is comprehensive and all made locally. It has the added advantage that the pipework can be dismantled and re-assembled, should the need arise. Cobra compression fittings is ideally suited for use in emergency repairs as well, for instance with the slip couplings D-1XL-15 S/C and D-1XL-22 S/C which can be used to make a repair connection to rigid pipework mounted close to a wall.

The fact that the complete connection is a metal to metal mechanical coupling makes it both permanent (no organic sealing material that can deteriorate), as well as being suitable for applications where the heat and open flames of soldered connections can pose a hazard.

With the introduction of SABS Specification 1067-2 in 1985 which required the use of DEZINCIFICATION RESISTANT BRASS, Cobra took steps to ensure that Cobra compression fittings complied with this specification.

Cobra commpression fittings can be used in conjunction with Cobra Safe Single Layer Polyethylene Pipe System as well as Cobra Safe Multi Layer Polyethylene Pipe System.

COPPER TUBING FOR ECONOMY

DZR Brass: All Cobra compression fittings are manufactured from Dezincification Resistant Brass as required by SANS 1067 Part 1 and 2 Specification.

Using Copper Tube Saves You Money In Many Ways:

- It is faster (over 50% in time can be saved)
- No thread cutting and extra costly labour giving increased output
- Prefabrication on large repetitive installations the system lends itself admirably to prefabrication – this is especially so when used in conjunction with Copcal capillary solder fittings
- No heavy equipment to transport

Advantages of Copper Tubing Systems:

- Excellent corrosion resistance, both internal and external
- Low in service maintenance (no furring)
- · Superior flow characteristics even after many years
- Space saving
- Neat appearance where exposed
- Shallower chasing in walls
- Cost effective in terms of overall installed cost
- · No heavy equipment required
- Light weight facilitating transport, fabrication and installation

Copper Builds Confidence!

MAKING A COMPRESSION JOINT



 Copper Tube can be cut with a hacksaw: a fine toothed blade is best, or use a roller tube cutter; Do not use too much pressure on the cutting disk.



2. Clean the ends of the tube with a file or de-burring tool, inside and outside.



3. The parts of the joint can be laid out like this before assembly.



4. Slide the copper tube into the Cobra compression fitting until it stops against the fitting's inner shoulder. Tighten the cap nut by hand, ensuring that the tube stays firmly against the fitting's inner shoulder.



5. Following hand tightening of the cap nut, tighten with a spanner until the copper tube is difficult to rotate in the compression fitting, thereafter tighten the cap nut through half a turn. Inspect and pressure test the joint pipe.

This compression joint is designed to be a metal to metal mechanical coupling (also applicable to Cobra SLP & MLP systems, no de-burring necessary); there is therefore no need for any additional sealant material or compounds.

D-1XS

Straight Coupler. Copper to Copper connections.

> 15mm; 22mm; 28mm; 35mm; 42mm; 54mm

* Also available D-1XL-12 S/C, D-1XL-15 S/C, D-1XL-18 S/C and D-1XL-22 S/C Slip Couplings (without internal pipe stops) for repairs or alterations to rigid pipework.

D-2XS

Straight Coupler. Copper to Male Iron connections.

> 15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"



D-3XS

Straight Coupler. Copper to Female Iron connections.

> 15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"



Reducing Straight Coupler. Copper x Copper connections.

> 22mm x 15mm; 28mm x 22mm



D-4XS

Elbow, 90°. Copper to Copper connections.

> 15mm; 22mm; 28mm; 35mm; 42mm; 54mm



D-4RXS

Reducing Elbow, 90°. Copper to Copper connections.

22mm x 15mm



D-2RXS

Reducing Straight Coupler Copper to Male Iron connections.

> 15mm x ¾"; 22mm x 1"



D-3RXS

Reducing Straight Coupler Copper to Female Iron connections.

15mm x ¾"



D-8XS

Elbow, 90°.

Copper to Male Iron connections.

15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"



D-10XS

Elbow, 90°. Copper to Female Iron connections.



15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"

D-33XS

Wallplate Elbow, 90°. Copper to Female Iron connections.

15mm x ½"; 22mm x ¾"



D-37XS

Swivel Elbow, 90°. Copper to Female Iron connections.

15mm x ½"



D-10RXS

Reducing Elbow, 90°. Copper to Female Iron connections.

15mm x ¾"



D-12XS

Equal Tee. Copper toCopper connections.

> 15mm; 22mm; 28mm; 35mm; 42mm; 54mm



D-15XS

Tee.

Copper to Copper to Male Iron connections.

15mm x 15mm x ½"; 22mm x 22mm x ¾"



D-17XS

Tee.

Copper to Copper to Female Iron connections.



15mm x 15mm x ½"; 22mm x 22mm x ¾"

D-29XS

Wallplate Tee. Copper to Copper to Female Iron connections.

15mm x 15mm x ½ "



D-17RXS

Reducing Tee. Copper to Copper to Female Iron connections.





D-279XS

Reducing Tee. All ends Copper. Run equally reduced.





D-280XS

Reducing Tee. All ends Copper. Run and Branch equally reduced.

22mm x 15mm x 15mm



D-79XS

Reducing Tee. All ends Copper. One end on Run reduced.

22mm x 15mm x 22mm



D-80XS

Reducing Tee. All ends Copper. Branch reduced.



22mm x 22mm x 15mm; 28mm x 28mm x 22mm

D-68XS

Single Step Reducer (for adapting a fitting)

22mm x 15mm; 28mm x 22mm; 35mm x 28mm; 42mm x 35mm; 54mm x 42mm



D-268XS

Multi-Step Reducer

28mm x 15mm; 35mm x 22mm; 42mm x 22mm; 42mm x 28mm; 54mm x 22mm; 54mm x 28mm; 54mm x 35 mm



64XS

Cap Nut

15mm; 22mm; 28mm; 35mm; 42mm; 54mm



D-65XS

Brass Compression Ring

15mm; 22mm; 28mm; 35mm; 42mm; 54mm



D-23XS

Stop End

15mm; 22mm; 28mm



62XS

Brass Holderbat for Copper Tube

15 mm; 22mm



GATE VALVES

1003/125

Fullway Gate Valve. Copper to Copper with non-rising spindle and guided wedge.

> 15mm; 22mm; 28 mm: 35mm: 42mm; 54mm





Use as an isolating valve ONLY SABS 776-1976, Class 8

STOP TAP

131

Stop Tap. Rough Brass. Copper to Copper

> 15mm; 22mm; SABS 28 mm; BS 1010

SABS 226 Class 1 Heavy duty



5**88**5

* Also available 231-15 Stop tap, Rough Brass, Copper to Copper; SABS 226 Class 2; SABS 226-1987, Type 1

INTRODUCTION

Capillary Fittings

Cobra introduced Capillary (or Solder) fittings to the South African market in 1972. These fittings were, at that time, imported and did not have much impact on the traditional compression type copper tube market. However, with the introduction of Hard Drawn Copper tubing, this system has gained in popularity, particularly in those areas where galvanised piping has been used traditionally. Hard Drawn Copper tubing, when used with Cobra "Copcal" fittings, can compare in cost with any conventional system.

In 1984 Cobra began local manufacture of these fittings to SABS Specification 1067 Part 2, and today still manufacture the forged and cast DZR brass fittings.

The comprehensive range of COBRA Capillary fittings conforms to SABS 1067 Part 2 1985 as well as to DIN 2856. ISO 2016 and BS 864 standard specifications.

The simple joining technique is a readily acquired skill and can be mastered with little difficulty. Users of Cobra Capillary fittings find this domestic plumbing much faster than any other.

The introduction of a Hard Drawn Copper tube, less expensive than the widely used domestic copper tube and conforming to SABS 460 Class "O", has made the choice of a copper tube installation a most economic proposition. The hard drawn tube when used with COBRA fittings, can compare in cost with any conventional system.

The savings in installation time, the competitive price of Hard Drawn Copper tube and Cobra Capillary fittings and the undeniable longevity of copper, all go to make the selection of this system sound economic sense.

NOTE:

Fittings with a "D-" prefix are manufactured from Dezincification Resistant Brass.

MAKING A CAPILLARY JOINT



 Copper Tube can be cut with a hacksaw: a fine toothed blade is best, or use a roller tube cutter; Do not use too much pressure on the cutting disk.



Clean the ends of the tube with a file or de-burring tool, inside and outside.



 Apply flux to the outside of tube and inside cup of fitting so that the surfaces to be joined are completely covered. Use flux carefully and sparingly.



4. Bend over end of solder wire - about the length of the size of the fitting. 15mm solder for 15mm fittings, etc. Over 50mm diameter approximately three times the diameter of the fitting is required.



 Apply flame to the fitting to heat the tube and the cop of the fitting until solder melts when placed at the joint, and then pass the flame towards the centre of the fitting until solder is absorbed and joint completed.



 Remove excess solder with small brush (or a dump cloth) while the plastic is leaving a fillet around end of fitting while it cools.

600M

Straight Slip Coupler Copper to Copper connections.

> 15mm, 22mm, 28mm, 35mm, 42mm, 54mm, 67mm, 76mm, 108mm.



Straight Coupler Copper to Copper connections.





601M

Reducing Straight Coupler Copper to Copper connections.

22mm x 15mm, 28mm x 15mm, 28mm x 22mm, 35mm x 28mm, 42mm x 35mm, 54mm x 42mm, 76mm x 35mm, 76mm x 42mm, 76mm x 54mm.



601M-TC

Straight Tap Connector. Copper to Female Iron connections.

15mm x ½"; 22 x ¾"



601-2M

Reducing Straight Coupler. Copper to Copper connections. (To reduce a fitting)

22mm x 15mm; 28mm x 15mm; 28mm x 22mm; 35mm x 15mm; 35mm x 22mm; 35mm x 28mm; 42mm x15mm; 42mm x 22mm 54mm x 28mm; 42mm x 35mm; 54mm x 28mm; 54mm x 25mm; 54mm x 42mm; 67mm x 35mm; 67mm x 54mm; 76mm x 35mm; 76mm x 54mm; 76mm x 67mm;

25

D603M

Straight Coupler. Copper to Female Iron connections.

> 15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"; 76mm x 3"



D603M

Reducing Straight Coupler. Copper to Female Iron connections.

15mm x ¾"



604M

Reducing Straight Coupler. Copper to Male Iron connections.

15mm x ¾"



D604M

Straight Coupler. Copper to Male Iron connections.



15mm x ½", 22mm x ¾", 28mm x 1", 35mm x 1¼", 42mm x 1½", 54mm x 2", 76mm x 3".

D606M

Elbow 45°. Copper to Copper connections.

> 15mm; 22mm; 28mm; 35mm; 42mm; 54mm; 76mm; 108mm



607M

Elbow 90°. Copper to Copper connections.



15mm; 22mm; 28mm; 35mm; 42mm; 54mm; 67mm; 76mm; 108mm

607M

Reducing Elbow 90°. Copper to Copper connections.

22mm x 15mm



607M-TC

Bent Tap Connector Copper to Female Iron connections

15mm x ½"; 22mm X ¾"



D707-3M

Reducing Elbow 90°. Copper to Female Iron connections.

15mm x ¾"



D707-3M

Elbow 90°. Copper to Female Iron connections.



15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"

D707-3-5M

Wallplate Elbow 90°. Copper to Female Iron connections.

15mm x ½" ; 22mm x ¾"



D707-4M

Elbow 90°. Copper to Male Iron connections.



15mm x ½"; 22mm x ¾"; 28mm x 1"; 35mm x 1¼"; 42mm x 1½"; 54mm x 2"

611M

Reducing Tee. All ends Copper. Run equally reduced.

15mm x 15mm x 22mm



611M

Equal Tee. All ends Copper.

> 15mm; 22mm; 28mm; 35mm; 42mm; 54mm; 67mm; 76mm; 108mm



611M

Reducing Tee. All ends Copper. Branch reduced.

22mm x 22mm x 15m; 28mm x 28mm x 15mm; 28mm x 28mm x 22mm; 35mm x 35mm x 15mm; 35mm x 35mm x 22mm; 35mm x 35mm x 28mm; 42mm x 42mm x 15mm; 42mm x 42mm x 22mm; 42mm x 42mm x 28mm; 42mm x 42mm x 35mm; 54mm x 54mm x 22mm; 54mm x 54mm x 28mm; 54mm x 54mm x 35mm; 54mm x 54mm x 42mm; 67mm x 67mm x 55mm; 76mm x 76mm x 35mm; 76mm x 76mm x 54mm; 76mm x 76mm x 76mm



611M

Reducing Tee. All ends Copper. One end on Run reduced.

> 22mm x 15mm x 22mm; 28mm x 22mm x 28mm



611M

Reducing Tee. All ends Copper. Run and Branch equally reduced.



22mm x 15mm x 15mm; 28mm x 22mm x 22mm

D712M

Reducing Tee. Copper to Copper to Female Iron connections.

> 15mm x 15mm x ½"; 22mm x 22mm x ¾"



D617M

Tube End Cap

15mm; 22mm; 28mm; 35mm; 42mm; 54mm



D733M

Union Coupler. Copper to Copper connections.

15mm; 22mm



733-3M

Union Coupler. Copper to Female Iron connections.

15mm x ½"



D733-4M

Union Coupler. Copper to Male Iron connections.

15mm x ½"; 22mm x ¾"



636M

Full Crossover. Copper to Copper connections.

15mm; 22mm



COPPER TUBING FOR DOMESTIC PLUMBING

Tubes for Domestic Plumbing Services as per SABS 460

Class 2 (Medium)

Nominal	Outside Diameter		Wall	Theoretical	Maximum Working
Size of Tube (mm)	Max (mm)	Min (mm)	Thickness Class 2 Med. (mm)	Mass kg/m Class 2	Pressure Mpa Class 2 Half Hard
15	15,045	14,955	1,0	0,392	7,54
22	22,055	21,945	1,0	0,588	5,00
28	28,055	27,945	1,2	0,900	4,72
35	35,070	34,930	1,5	1,407	4,72
42	42,070	41,930	1,5	1,701	3,81
54	54,070	53,930	2,0	2,912	4,06
76	76,170	76,030	2,0	4,150	2,85
108	108,070	107,930	2,5	7,385	2,50

Class 1 (Light)

Nominal	Outside Diameter		Wall	Theoretical	Maximum Working
Size of Tube (mm)	Max (mm)	Min (mm)	Thickness Class 1 Med. (mm)	Mass kg/m Class 1	Pressure Mpa Class 1 Half Hard
15	15,045	14,955	0,70	0,280	5,16
22	22,055	21,945	0,90	0,532	4,50
28	28,055	27,945	0,90	0,683	3,50
35	35,070	34,930	1,20	1,136	3,74
42	42,070	41,930	1,20	1,371	3,03
54	54,070	53,930	1,20	1,774	2,40
76	76,170	76,030	1,50	3,133	2,12
108	108,070	107,930	1,50	4,473	1,49

COPPER TUBING FOR DOMESTIC PLUMBING

Class 0

Nominal	Outside [Diameter	Wall	Theoretical Mass kg/m Class 0	Maximum Working Pressure Mpa Class 0 Half Hard
Size of Tube (mm)	Max (mm)	Min (mm)	Thickness Class 0 Med. (mm)		
15	15,045	14,955	0,60	0,242	4,93
22	22,055	21,945	0,75	0,447	4,18
28	28,055	27,945	0,80	0,610	3,59
35	35,070	34,930	1,20	1,137	4,20
42	42,070	41,930	1,20	1,372	3,48
54	54,070	53,930	1,20	1,775	2,69
76	76,170	76,030	1,50	3,133	2,38
108	108,070	107,930	1,50	4,473	1,67





Tel: 0861 21 21 21 Email: marketing@cobrawatertech.co.za www.cobra.co.za

